

TOWN OF CHESTER WATER DEPT.

MONTHLY REPORT- MAY 2025

The water department processed and distributed 7,077,031 gallons of water for the month of May. The districts daily average ranged from 210 to 90,400 gallons. The breakdown is:

Lake Hill Farms- 2,803,000 gal.

Sugar Loaf- 1,448,5600 gal.

Surrey Meadows- 1,578,100 gal.

Walton Lake Estates- 1,042,100 gal.

Fieldcrest- 198,700 gal. (Distribution only)

Town Hall- 6,531 gal.

Distribution sampling by us as well as random sampling by Orange County DOH showed adequate disinfection levels, and tested negative for any type of bacteria.

Monthly DOH 360 forms and test results for 4/2025 on all districts were submitted to DOH on 5/9/2025

Laboratory testing dates were 5/7 & 5/21

Mowing dates at the plants were 5/8, 5/19, 5/20 & 5/27

Bulk chemicals were delivered on t

Other Business:

Sugar Loaf was mostly quiet with routine operations and maintenance. Started the investigation at Well 2 with help from Turnbull Well drilling.

Surrey Meadows was mostly quiet with routine operations and maintenance. Fixed shut off at 27 Park due to a bad flare to the shut off. 9 Price Road has leak under foundation and is home owners' responsibility.

Lake Hill Farms was mostly quiet with normal operations and maintenance. Cleaned up trees and plants around the two water towers. Located water shut off at 39 Wilson and needs to be replaced. Continued doing the installations of endpoints. 39 Wilson replaced shut off in driveway with help from highway. Cut the road for replacing service lines at 39 & 47 Wilson Road due to both having multiple leaks under main road. Replaced service line at 39 Wilson

Road with help from highway and TAM to vac around gas main and electric. Then replaced 47
Wilson Road next day with help from highway and TAM to vac around gas main and electric.

Walton Lake Estates was mostly quiet with routine operations and maintenance.

Fieldcrest was quiet with routine operations and maintenance.