

TOWN OF CHESTER WATER DEPT.

MONTHLY REPORT- FEBRUARY 2026

The water department processed and distributed 6,575,244 gallons of water for the month of February. The districts daily average ranged from 380 to 92,000 gallons. The breakdown is:

Lake Hill Farms- 2,564,000 gal.

Walton Lake Estates- 1,201,800 gal.

Sugar Loaf- 1,399,800 gal.

Surrey Meadows- 1,146,900 gal.

Town Hall- 10,644 gal.

Fieldcrest- 252,100 gal. (Distribution only)

Distribution sampling by us as well as random sampling by Orange County DOH showed adequate disinfection levels, and tested negative for any type of bacteria.

Monthly DOH 360 forms and test results for January 2026 on all districts were submitted to DOH on 2/10/2026

Laboratory testing dates were 2/4 & 2/18

Snow cleanup dates at the plants were 2/9 & 2/23

Chemical deliveries 2/19

Water withdrawal reports completed for the DEC

Other Business:

Sugar Loaf was mostly quiet with routine operations and maintenance. Shut off two street valves on Pine Hill rd and Creamery Pond road to isolate a leak and stop it from leaking until warmer weather to dig up and fix. Not affecting anyone's service lines.

Surrey Meadows was mostly quiet with routine operations and maintenance. Continued installing endpoints.

Lake Hill Farms was mostly quiet with normal operations and maintenance. Quackenbush came and replaced well motor and well pipe at well F4.

Walton Lake Estates was mostly quiet with routine operations and maintenance. Located a leak in Lake Region by listening to the shut offs and determined it was at 2 Cambridge Cr. We fixed the saddle leak in March.

Fieldcrest was quiet with routine operations and maintenance. Replaced the locks on both doors of the water plant to a new set so only the 3 operators have them.