

TOWN OF CHESTER WATER DEPT.

MONTHLY REPORT – APRIL 2026

The water department processed and distributed 6,236,103 gallons of water for the month of March. The districts daily average ranged from 280 gallons to 82,000 gallons. The monthly breakdown is:

Lake Hill Farms- 2,448,000 gal.

Walton Lake Estates- 865,400 gal.

Sugar Loaf- 1,355,400 gal.

Surrey Meadows-1,282,200 gal.

Town Hall- 8,403 gal.

Fieldcrest- 276,700 gal. (Distribution only)

Distribution sampling by us as well as random sampling by Orange County DOH showed adequate disinfection levels and tested negative for any signs of bacteria.

Monthly DOH 360 forms and test results for March were submitted on 4/10/26.

Laboratory testing dates were 4/1 & 4/

Annual Hydrant flush was conducted from 4/6 to 4/13

Mowed 4/17, 4/20, 4/21, 4/27, 4/28

Class for water credits at Wallkill on 4/9

All 3 generators were serviced by Peak Power.

Other Business:

Walton Lake Estates was quiet with routine operations and maintenance.

Sugar Loaf was quiet with normal operation and maintenance. Started doing maintenance on hydrants throughout the district.

Surrey Meadows was mostly quiet with normal operation and maintenance. Continued doing endpoints throughout the district. Replaced well motor at well 6 due to failure and warranty work and was done by Quackenbush. Fixed and replaced shutoff stem and riser in the yard at 9 Vivian with help from Hwy dept.

Lake Hill Farms was quiet with routine operations and maintenance.

Fieldcrest was mostly quiet with normal operation and maintenance. Turned the water back on for the park's bathrooms and food building on 4/10. Highway replaced torn belt on generator at the plant.