

TOWN OF CHESTER WATER DEPT.

MONTHLY REPORT – MARCH 2026

The water department processed and distributed 6,039,994 gallons of water for the month of March. The districts daily average ranged from 422 gallons to 69,000 gallons. The monthly breakdown is:

Lake Hill Farms- 2,128,000 gal.

Walton Lake Estates- 1,030,200 gal.

Sugar Loaf- 1,344,800 gal.

Surrey Meadows-1,282,200 gal.

Town Hall- 13,094

Fieldcrest- 264,800 gal. (Distribution only)

Distribution sampling by us as well as random sampling by Orange County DOH showed adequate disinfection levels and tested negative for any signs of bacteria.

Monthly DOH 360 forms and test results for February were submitted on 3/6/26.

Laboratory testing dates were 3/4 & 3/18

Quarterly meter reading conducted at all districts from 3/9-3/13

Annual Water Quality Reports we completed on 3/18

Attended Dig Safe NY class in rockland County on 3/5

Chemicals were delivered 3/26

Greens of Chester started to pressure test the new Water mains and passed

Other Business:

Walton Lake Estates was quiet with routine operations and maintenance. Had a broken water main saddle on Cambridge Cr, Had TAM there to help with their vac truck due to underground electric over the main. Dropped off new control panel and booster pump system to the plant to be installed in the future. Had to dig up 3 maple lane to repair clogged sewer service from a water main break we did over the winter, had help from Hwy and Monda Basin. 14 Tulip water service was shut off due to house fire.

Sugar Loaf was quiet with normal operation and maintenance. We installed two new chlorine pumps at the plant that work with the analyzer to inject proper amount at all times, TAM came ad did the wiring and programming for us.

Surrey Meadows was mostly quiet with normal operation and maintenance. Continued doing endpoints throughout the district.

Lake Hill Farms was quiet with routine operations and maintenance.

Fieldcrest was mostly quiet with normal operation and maintenance.