

TOWN OF CHESTER WATER DEPT.

MONTHLY REPORT- JUNE 2026

The water department processed and distributed 7,098,323 gallons of water for the month of June. The districts daily average ranged from 437 to 76,000 gallons. The breakdown is:

Lake Hill Farms- 2,284,000 gal.

Walton Lake Estates- 1,240,800 gal.

Sugar Loaf- 1,660,400 gal.

Surrey Meadows- 1,583,500 gal.

Town Hall- 13,123 gal.

Fieldcrest- 316,500 gal. (Distribution only)

Distribution sampling by us as well as random sampling by Orange County DOH showed adequate disinfection levels, and tested negative for any type of bacteria.

Monthly DOH 360 forms and test results for 5/2026 on all districts were submitted to DOH on 6/10/2026

Laboratory testing dates were 6/3 & 6/19

Mowing dates were 6/1, 6/8, 6/10, 6/16

Chemicals were delivered 6/11

Did Meter read at all districts from 6/4-6/5

We helped the highway dept flag on Pine Hill Rd for milling of roadway on 6/25

Had Class for water license at Wallkill on 6/18

Other Business:

Sugar Loaf was mostly quiet with routine operations and maintenance. Replaced stem and riser on the shutoff in the yard at 25 Meri with help from Highway and Monda for vac truck.

Surrey Meadows was mostly quiet with routine operations and maintenance. Continued to install endpoints throughout.

Lake Hill Farms was mostly quiet with normal operations and maintenance. Did more endpoints, have a few opt outs and handful left to do waiting on responses.

Walton Lake Estates was mostly quiet with normal operations and maintenance. TAM came and swapped over the old control panel to the new one in one day. Quackenbush came and replaced pump and well pipe at well F4. TAM came to wire up new generator transfer switch in the plant. As of 6/22 the new Panel and Booster set up is fully complete and operational. Replaced stem and riser for shut off in yard at 40 Poplar with help from highway.

Fieldcrest was quiet with routine operations and maintenance. Peak power replaced the starter and plugs on the standby generator.

Greens of Chester was quiet. They chlorinated the water mains in the first section of property. Installed a total of 6 meters on 6/22 and 5 more on 6/26.