

## **TOWN OF CHESTER WATER DEPT.**

### **MONTHLY REPORT- JULY 2026**

The water department processed and distributed 7,415,881 gallons of water for the month of July. The districts daily average ranged from 367 to 89,000 gallons. The breakdown is:

Lake Hill Farms- 2,776,000 gal.

Walton Lake Estates- 1,288,400 gal.

Sugar Loaf- 1,615,600 gal.

Surrey Meadows- 1,461,900 gal.

Town Hall- 11,381 gal.

Fieldcrest- 259,600 gal. (Distribution only)

Distribution sampling by us as well as random sampling by Orange County DOH showed adequate disinfection levels, and tested negative for any type of bacteria.

Monthly DOH 360 forms and test results for 6/2026 on all districts were submitted to DOH on 7/10/2026

Laboratory testing dates were 7/1 & 7/15

Mowing dates at the plants were 7/8, 7/10, 7/13, 7/20, 7/27

Bulk chemicals were delivered on the 7/10

Started 2027 Budget work

Other Business:

Sugar Loaf was mostly quiet with routine operations and maintenance. Started to exercise the hydrants throughout the district. Fixed leaking street valve at Pine Hill and Creamery Pond Rd. Replaced the bolts in two of the valves and removed one valve and put a 10" cap on it.

Surrey Meadows was mostly quiet with routine operations and maintenance. Replaced a stem and riser in the yard at 83 Surrey rd.

Lake Hill Farms was mostly quiet with normal operations and maintenance. Pressured was the outside of the newer water tower. Service line leak at 5 Harrison pl, replaced a section of copper to the house.

Walton Lake Estates was mostly quiet with routine operations and maintenance. Water main break at 3 Maple Ln overnight. Had a water main break at 10 Oak Dr. #1 Maple Ln we located and installed a shut off in their yard on the service line.

Fieldcrest was quiet with routine operations and maintenance.