

TOWN OF CHESTER WATER DEPT.

MONTHLY REPORT- AUGUST 2026

The water department processed and distributed 6,849,687 gallons of water for the month of July. The districts daily average ranged from 602 to 83,000 gallons. The breakdown is:

Lake Hill Farms- 2,583,000 gal.

Walton Lake Estates- 1,160,300 gal.

Sugar Loaf 1,565,700 gal.

Surrey Meadows- 1,278,600 gal.

Town Hall-18,687 gal.

Fieldcrest- 243,400 gal. (Distribution only)

Distribution sampling by us as well as random sampling by Orange County DOH showed adequate disinfection levels, and tested negative for any type of bacteria.

Monthly DOH 360 forms and test results for 7/2026 on all districts were submitted to DOH on 8/7/2026

Laboratory testing dates were 8/5 & 8/19.

Mowing dates at the plants were 8/5, 8/24

Chemicals were delivered 8/20

Started installing meters at the Greens for their CO's

Other Business:

Sugar Loaf was mostly quiet with routine operations and maintenance. Replaced the old meter in the pit for 53 Wood Rd. Had an emergency water main break on Wright and Meri rd from fire dept hammering the mains, blew the bolts out of a street valve, had to replace street valve and section of pipe, help from Monda and Highway.

Surrey Meadows was mostly quiet with routine operations and maintenance.

Lake Hill Farms was mostly quiet with normal operations and maintenance. Replaced the hydrant at 25 Lincoln rd, had help from Modna, Highway and Tam due to an emergency that

occurred. Had to replace the bolts on two street valves at the intersection of Lincoln and Tyler, help from Highway and TAM. We replaced the entire service line at 40 Linclon rd due to several leaks and old fixes, help from Highway and Monda.

Walton Lake Estates was mostly quiet with routine operations and maintenance. Replaced stem and riser at 7 Poplar Dr help from Highway.

Fieldcrest was quiet with routine operations and maintenance.