TOWN OF CHESTER WATER DEPT.

MONTHLY REPORT- SEPTEMBER 2026

The water department processed and distributed 6,436,759 gallons of water for the month of September. The districts daily average ranged from 371 to 80,000 gallons. The breakdown is:

Lake Hill Farms- 2,399,000 gal.

Walton Lake Estates- 1,075,900 gal.

Sugar Loaf- 1,444,300 gal.

Surrey Meadows- 1,258,300 gal.

Town Hall- 11,159 gal.

Fieldcrest- 200,600 gal. (Distribution only)

Distribution sampling by us as well as random sampling by Orange County DOH showed adequate disinfection levels, and tested negative for any type of bacteria.

Monthly DOH 360 forms and test results for 8/2025 on all districts were submitted to DOH on 9/4/26

Laboratory testing dates were 9/2 & 9/16

Mowing dates 9/11, 9/18, 9/22, 9/24

Chemical Delivery of Bulk supplies was on 9/24

Meter Reading was started on 9/15 and ended on 9/17

Other Business:

Sugar Loaf was mostly quiet with routine operations and maintenance. Well 1a had a 4x3 bushing on the pitless blow out so we had to vac around the well with TAM and replace the bushing with a new galvanized one. We replaces the bolts on the two street valves at intersection of Pine Hill and Wood rd with help from highway and Monda. Prepped new well site at well 2 by the plant so we can have the new well drilled by the beginning of November.

Surrey Meadows was mostly quiet with routine operations and maintenance. House of rt94 had a service line leak repaired by WJ Ebner since it was after out shutoff.

Lake Hill Farms was mostly quiet with normal operations and maintenance. We replaced the entire service line from shut off to the main at 36 Lincoln Rd with help from Tam Vac truck and

Highway digging. We replaced rusted and broken bolts on the street valves at intersection of Lincoln and Wilson help from highway and Monda.

Walton Lake Estates was mostly quiet with routine operations and maintenance.

Fieldcrest was quiet with routine operations and maintenance.